

November 2021 Fire Marshal Report

896 Taylor Dr.

11/04/2021 Follow up to smoke detector activation. Replaced batteries in 3 units all system working as designed.

1525 Woodland Ave.

11/05/2021 Follow up to bathroom fire on 11/03 defective bathroom vanity light arching and set trash can on fire. Bathroom being worked on by contractor and electrical issues were resolved as of 11/11

936 Taylor Drive.

11/16/2021 Follow up to burnt food and no smoke alarms. 2 smoke detectors given to resident to be installed.

132 Folcroft Ave. Apt 112

11/17/2021 Oven malfunction follow up from 11/16. Unit still out of service.

11/19/2021 new oven installed by maintenance. OK

807 Bennington Rd.

11/24/2021 CO detector follow up. All 3 detectors replaced 2 out of date and 1 as a precaution. 2 smoke detectors recommended to be added to basement and front bedroom.

1870 Delmar Drive

11/29/2021 Follow up to building fire. Tent still waiting on Insurance company to ok repairs and clean up. Will have more information on Dec. report.