

## December 2021 Fire Marshal Report

### **1870 Delmar Drive**

11/29/2021 Follow up to building fire. Tenant still waiting on Insurance company to ok repairs and clean up. Will have more information on Dec. report.

12/14/2021 Insurance company making progress. Clean up and repairs moving forward.

### **132 Folcroft Ave.**

12/7/2021 Follow up to Alarm system activation only sounding on 1<sup>st</sup> floor. Delco alarm system repairman on location verified all audible devices working at this time

### **600 Grant Rd Apt 21a and b**

12/9/2021 Follow up for alarm system repair. Water leak caused damage to basement detector. Leak repaired new alarm head installed.

### **1525 Virginia Ave**

12/28/2021 Follow up to carbon monoxide alarm. Peco red tag heater/water boiler on 12/27/2021.

12/30/2021 New burner installed in unit verified repair. Red tag removed. System operating as designed