

January 2022 Fire Marshal Report

3014 Heather Rd.

1/2/2022 Responded to above address for fire investigation. Bedroom fire 2nd floor front. Oil filled electric heater plugged into light weight extension cord plugged into surge protector. Cord and surge protector under a large pile of clothes. Heater switch was in on position. Bathroom/Front Bedroom circuit breaker tripped. No One home at time of fire. Photos taken.

1/4/2022 Met with owner and insurance adjuster. Owner advised of what was found.

1/11/2022 Met with Fire investigator from Farmers Insurance Company. To review findings. Claim on going.

917 Delview Dr.

1/3/2022 Follow up to Microwave fire that caused outlet damage. Electrician replaced outlet microwave no longer at residence.

1063 N. Academy Ave. DT

1/11/2022 Assisted FM46 per DC77 with resident interview about house fire. Accidental fire started while smoking in bed. Dropped cigarette onto bed coverings. Photos taken.

1540 Chester Pike

1/14/2022 Follow up to grass fire caused by shorted electrical wiring at sign post. Owner stated electrician contacted to remove wiring. Sign no longer used.

2051 Heather Rd.

1/15/2022 House fire started during domestic issue. FM63 assisted Officer White. See Officer White report for full details if needed. Due to a Police matter.

770 Taylor Drive

1/27/2022 Follow up to Heater malfunction on 1/26. Heater service company on location performing repairs. System working as designed after repairs.

1095 Taylor Drive

Follow up to illegal burning in fire pit. Met with home owner explained borough ordinances. Property not large enough to have fire pit. Will continue to monitor property.