

May 2021 Fire Marshal Report

5/25/2021 Nuisance Alarm at 132 Folcroft Ave. System malfunctioning causing activation but not transmitted to Delco Alarm system. Tenants called 911 due to alarm sounding in building. Talked to Nancy alarm company notified.

5/28/2021 Nuisance Alarm at 132 Folcroft Ave. System still Malfunctioning causing activation but not transmitting to Delco Alarm system. Spoke with representative from Delco Alarm system will be worked on 5/29/2021. Contacted Joe Donnelly Code Enforcement to advise him of situation.

6/3/2021 132 Folcroft Ave Alarm system still malfunctioning. Several other fire hazards noted while investigating alarm sounding. Code enforcement notified and several pictures taken of wiring issues and fire alarms hanging from 3rd floor ceiling. Apartment 123 hole in floor in bathroom, Apartment 208 Entry door falling off, Main entrance alarm electrical panel open with live wires exposed and Garage areas cluttered with wood and other debris. Some work is completed as of 6/9/2021 work still in process on Alarm system.