

## July 2021 Fire Marshal Report

### **4 School Lane**

7/5/2021 Hazmat Refrigerant Leak FD responded to loud his noise. 3000 Liter Nitrogen tank leaking from valves. County Hazmat representative responded. Scene turned over to County Officials. Fire Marshal and Fire Company stood by while leak was contained by private contractor (Keen Environmental). Air monitoring done no need for evacuations. Tank not registered with county or state. County Officials to follow up.

7/7/2021 Follow up inspection done by Fire Marshals office with County Hazmat Rep. Registration and all paperwork filed all appropriate signed installed and warning signs visible. County Rep will advise when complete.

### **1505 Elmwood Ave. Apt 7**

7/13/2021 Appliance Fire 6 Y.O. daughter trying make herself food. Accidental

7/14/2021 Follow up Damaged Air Fryer and Toaster both removed from residence by tenant. For safety concerns. Landlord advised of incident.

### **600 Grant Rd Apt 2**

7/16/2021 Fire Alarm System shorted due to water leak on 1<sup>st</sup> floor. Power and Water secured by FD. Garage ceiling removed. Fire alarm and Electrical system shorted. Landlord unable to be reached. Code Enforcement notified and responded. Tenants advised they could not stay in residence without utilities.

7/21/2021 Follow up inspection repairs made and fire alarm system repaired. All systems restored to normal operating design.

### **1000 Ashland Ave.**

7/20/2021 Fire Alarm system Malfunction Follow up inspection. No system service has been performed.

7/21/2021 Nuisance Alarm letter sent warning of any other false alarms will result in fines being issued.

**2031 Kent Rd.**

7/24/2021 Follow up to defective Carbon monoxide alarm. New alarms installed by home owner.

**2027 Heather Rd.**

7/26/2021 Follow up to defective carbon monoxide Alarm. New alarms purchased not yet installed.

7/28/2021 second follow up new alarms installed.