

November 2020 Fire Marshal Report

11/19/2020 Inoperative Fire Alarm system at 1850 Delmar Drive Save-A-Lot Food store. Fire Company dispatched for fire Alarm. No alarm sounding store not evacuated upon fire company arrival. Store management unaware of system transmitting false alarms. Fire Marshal notified management to have service look at system with in 48 hours.

11/20/2020 Inoperative Fire Alarm system at 1850 Delmar Drive Save-A-Lot Food store. Fire Company dispatched for fire Alarm. No alarm sounding store not evacuated upon fire company arrival. Store management unaware of system transmitting false alarms. Fire Marshal notified by Capt. 1 via phone. Fire Marshal followed up with district manager and regional director. Service tech on scene 11/21/2020 replaced fire alarm system panel.

11/22/2020 Follow up letter sent to Save-a-lot regional director in regards to nuisance alarms as per borough ordinance.

11/24/2020 Inoperative Fire Alarm system at 1850 Delmar Drive Save-A-Lot Food store. Fire Company dispatched for fire Alarm. Fire Marshal contact by 911 Center at 10:52 am request of Station 1 command. Followed up with Regional manager and service company at 15:36 . New phone line to unit and transmitter installed on 11/24/2020. System fully operational.